



जा.क.जि.प्र.शा. 158 12023 बि. 26/06/2023
जिल्हा प्रयोगशाळा, बुलडाणा

DISTRICT WATER TESTING LABORATORY

Office of Senior Geologist
Ground Water Surveys & Development Agency
BULDANA



WATER ANALYSIS TESTING REPORT

Name of Customer	-	Principal, Sanskar Dnyanpeeth.
Address of Customer	-	Aadarsh Nagar, Khamgaon, Dist- Buldana
Order / Reference	-	Your Letter Dated 22 / 06 / 2023
Nature of Sample	-	Potable water / Groundwater / Surface Water / Treated Water / Tap Water
Sample drawn & collected by	-	Principal, Sanskar Dnyanpeeth
Sample Condition	-	Clean / Clear / Good
Sample Received on	-	22 / 06 / 2023
Dates of Tests	-	23 / 06 / 2023
Temperature	-	25° ± 2° C
Report Issue on	-	26 / 06 / 2023
Sample Container	-	Glass / Plastic

PARAMETER RESULT

Parameters	Desirable limit	Permissible limit	Unit	Water Sample Result
pH	6.5-8.5		-	7.1
Electrical Conductivity	-	-	µs/cm	187
Total Dissolved Solid	500	2000	mg/l	122
Total Hardness	300	600	mg/l	64
Fluoride	1	1.5	mg/l	0.0
Nitrate	45	-	mg/l	10
Iron	0.3	-	mg/l	0.0
Total Alkalinity	200	600	mg/l	40
Chloride	250	1000	mg/l	28
Sulphate	200	400	mg/l	11
Turbidity	5	15	NTU	0.0
E. Coliform	0	0	MPN/100ml	00
Total Coliform	0	0	MPN/100ml	00

WATER SAMPLE DETAILS

Sr. No.	Sample Code No.	District	Taluka	Village	Particulars	Source
1.	DWTL/ 06 -23 / 23-24	Buldana	Khamgaon	Khamgaon	Treated water	Ro

Note

- The results relate only to the samples tested. The report shall not be reproduced except in full, without the written approval of the laboratory.
- The analysis is done on sample submitted by customer themselves.

Alexandra
Mrs A B Lokhande
Technical Manager
D.W.T.L., G.S.D.A. Buldana.

S. N. Davhale
Mr. S. N. Davhale
Authorized By / (Mr. Chief)
Quality Manager
D.W.T.L., G.S.D.A. Buldana.

Senior Geologist
CEO/Senior Geologist
GSDA Buldhana
G.S.D.A. Buldhana

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1KMC/51/2023



Dated: 21/06/2023

It is certified that an inspection team headed by Anant I. Nile Sanitary Inspector,
(Name of Officers with designation) from Municipal Council Khamgaon,

(Name of Department/ Office) inspected the -

SANSKAR DNYANPEETH, ADARSH NAGAR, KHAMGAON, DIST: BULDANA

on 17/6/2023 (date of inspection) and found that the -

SANSKAR DNYANPEETH, ADARSH NAGAR, KHAMGAON DIST: BULDANA has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of (31/3/2026) 3 years,



Signature with Seal:

Nakar

Chief Officer

Name

: **Municipal Council, Khamgaon**

Designation

:

Name & Address of the Office / Department :

To

Principal,

Sanskar Dnyanpeeth, Khamgaon,

(Name & Address of the Institution)